SSO Bypass Event
Tracker

Event Codes 1= SSO 2= Bypass 3= Basement

| Date | | Time | | Location | | Rainfall | Approx. | | Sample |
|----------|----------|----------|---------|------------------|-------|----------|-----------|-----------------|--------------|
| Begin | End | Begin | End | Manhole Segment | Event | Amount | Discharge | Reporting Party | Taken Y/N |
| 05/26/14 | 05/27/14 | 6:30 PM | 6:53 AM | 1801 E. Broadway | 2 | 1.35" | 1.4 | Joe Cornell | Υ |
| 06/09/14 | 06/10/14 | 8:45 PM | 6:15 AM | 1801 E. Broadway | 2 | 1.10" | 0.96 | Joe Cornell | Y |
| 07/08/14 | 07/09/14 | 6:00AM | 6:30AM | 1801 E. Broadway | 2 | 1.65" | 2.224 | Joe Cornell | Y |
| 09/01/14 | 09/02/14 | 4:30 AM | 7:50 AM | 1801 E. Broadway | 2 | 1.91" | 1.7 | Stephen Myrick | Υ |
| 09/17/14 | 09/17/14 | 12:00 PM | 2:30 PM | J4-MH-120 | 1 | 1.97" | 47,000 | Joe Cornell | N |
| 10/09/14 | 10/14/14 | 3:50 PM | 7:40 AM | 1801 E. Broadway | 2 | 2.78" | 6.27 | Joe Cornell | Υ |
| 10/10/14 | 10/10/14 | 7:30 AM | 1:00 PM | 1801 E. Broadway | 1 | 2.78" | 75,000 | Joe Cornell | N |
| 10/13/14 | 10/14/14 | 7:40 AM | 6:10 AM | 1801 E. Broadway | 2 | 1.27" | 3.35 | Joe Cornell | Y |
| 11/04/14 | 11/04/14 | 8:00AM | 8:30AM | F5-MH-010 | 1 | 1" | 800 | James Bradshaw | N |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

| Personnel, arrival time, & Remedy |
|--|
| Plant Hydraulically overloaded |
| Plant Flow Lowered. |
| Plant Hydraulically overloaded |
| In the 15 minutes it took crews to arrive with the jetter, the SSO stopped surfacing out of manhole. Crews Jetted roots out of main. |
| |
| |
| |
| |
| |
| |
| |